

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2014

2015 JUL -2 AM 8:08

City of McComb MS

Public Water Supply Name

570004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☐ Advertisement in local paper (attach copy of advertisement)  
☐ On water bills (attach copy of bill)  
☐ Email message (MUST Email the message to the address below)  
☐ Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ , \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 06 / 29 / 2015

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

- ☐ As a URL (Provide URL \_\_\_\_\_)  
☐ As an attachment  
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

\_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Sabrina England, President  
Name/Title (President, Mayor, Owner, etc.)

07/01/2015  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601) 576-7800

May be emailed to:  
[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2013*	3.9	No Range	ppb	n/a	10	Erosion of natural c from orchards; ero and electronics pro
10. Barium	N	2013*	.0216	No Range	ppm	2	2	Discharge of drilling discharge from the erosion of natural c
12. Cadmium	N	2013*	1.6	No Range	ppb	5	5	Corrosion of galval erosion of natural c discharge from me runoff from waste l paints
14. Copper	N	2011/13*	.1	0	ppm	1.3	AL=1.3	Corrosion of house systems; erosion c deposits; leaching preservatives
16. Fluoride**	N	2013*	.741	No Range	ppm	4	4	Erosion of natural additive which pro teeth; discharge fr and aluminum fac
17. Lead	N	2011/13*	3	0	ppb	0	AL=15	Corrosion of hous systems; erosion c deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2014	6	1 - 6	ppb	0	60	By-Product of drin disinfection.
Chlorine	N	2014	1	.90 – 1.2	mg/l	0	MDRL = 4	Water additive us microbes

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds requirements. We have learned through our monitoring and testing that some constituents have been detected; determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, we notify systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead is primarily from materials and components associated with service lines and home plumbing. City of McComb is responsible for quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting in pipes or containers for hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking, cooking, or baby formula. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF McCOMB is required to report results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride levels were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous year that were within the optimal range of 0.7-1.3 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, is expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by drinking water containing microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

The City of McComb works around the clock to provide top quality water to every tap. We ask that all our customers conserve water, which is the heart of our community, our way of life and our children's future.

# 2014 Annual Drinking Water Quality Report

PWS ID# 00570004



2015 JUL -2 AM 8: 08